



Table 1

Pos.	Quant.	Description
1	1	Body 1
2	1	Body 2
•• 3	1	Ball
•• 5	1	Stem
• 6	1	Stem seal
• 7	1	Stem packing
• 7d	1	Stem packing d
8	1	Gland packing
8a	1	Gland packing a
9	2 or 3	Spring washer
11	1	Cover
13	-	Cover bolt
• 14	1	Body seal 1
15	-	Body bolt
16	1	Handle
17	1	Handle bolt
•• 19	1	Spring
•• 20	1	Antistatic ball
• 34	1	Body seal 2
44b	2	Seat ring 2
45	-	Seat spring
• 46	2	Seat seal
•• 47	2	Metallic seat
•• 50	1	Subjection ring
86	1	Drain plug
• 109	1	Cover seal
• 127	1	Stem bearing
128	1	Body cover 2
163	-	Body cover 2 bolt
• 165	1	Stem bearing
167	1	Stem guide bolt

- Start-up: 5% of ordered quantity
- SOFT PARTS KIT
- METALLIC PARTS

Suggested materials to be checked at least every five (5) year service.

See point 5 (Maintenance)

Torque screw tightness values for bolts (Nr. 15) can be found attached in document DC-08-07-03 PF "Screw torque".

1. SCOPE

This manual is intended as a guide to assist customers or end-users in the correct storage, installation and maintenance of PEKOS guided valves.

2. APPLICABILITY

This manual is applicable to PEKOS guided ball valves (Z system) as per norm DIN two pieces with full bore metallic seats and 2 ways. Nominal sizes and pressures covered by this manual: PN 10-40 DN50-100.

3. STORAGE

3.1 Supplying conditions

Carbon steel ball valves are supplied with a phosphatising treatment to protect against corrosion. These conditions are standard, but they can be changed on demand.

3.2 Maintenance during the storage

- a. Stainless steel and carbon steel valves should be stored separately, to protect the stainless steel against corrosion.
- b. Valves must remain in open position with plastic end covers fitted.
- c. If possible it would be advisable to leave the ball valves in their own packing cases.
- d. Valves to be stored for a long time shall be checked by the quality control personnel every 6 months.
- e. Degreased valves shall only be unpacked before installation.

3.3 Environment conditions

- a. Valves shall be stored in dry conditions. Other corrosive environment conditions must be also avoided.
- b. Valves must be protected against ambient dust.

4. INSTALLATION

- a. Verify that valves have not been damaged during transit. Inspect inside of the valves and the pipeline of the installation to be able to verify there are no strange particles.
- b. It is advisable to use protective filters during the installation and check-in period while the possibility of dirt or even oxidation of the pipes exists. They have to be used until pipes are absolutely free of particles in suspension.
- c. If possible, valve shall be mounted in such way to allow periodic inspections.
- d. Valves are bidirectional, so fluid can run in both directions.
- e. Valves can be mounted in any position but it is advisable to mount the valves with the stem in vertical position.
- f. It is necessary to obtain correct alignment and parallelism to avoid any kind of stress.
- g. Once the installation is completed, valve must be operated for at least one opening and closing action to ensure perfect operation.
- h. After cleaning, protective filters could be removed.
- i. Protective filters should remain installed on dirty applications.

5. MAINTENANCE

Pekos recommends inspecting the valves at least every five (5) years. These inspection intervals could be affected by the process service (fluid, temperature, service, and cycles), and environmental condition.

5.1 Valves revision

PEKOS ball valves do not need lubrication and the packing does not need maintenance.

Stem seal (6), stem packing (7 and 7d), body seals (14 and 34), seat seal (46), cover seal (109), stem bearings (127 and 165) and stem (5) can be replaced easily using common tools. As replacement pieces is advisable to follow the instructions below table1 in page 1.

Prior to carrying out work on valves the pipeline must be completely empty, including the ball valve body cavity by half opening valve to allow any pressure build up to escape.

Care must be taken to avoid contact with dangerous or toxic chemical products. The valves must be thoroughly cleaned, in particular the body cavity, before handling and dismantling.

5.2 Stem leakage

The packing system of the *stem (5)* of PEKOS DIN ball valves has been designed for a long life. The *spring washers (9)* compensate any looseness inside the packing. In case of leakage, the stem seals shall be replaced as it is shown:

- a. If the valve contains handle, loosen the *handle bolt (17)* and remove the *handle (16)*.
- b. Loosen the *cover bolts (13)* and the *cover (11)* together with the *subjection ring (50)* and the *stem bearing (165)*.
- c. Remove the *spring washers (9)*, the *gland packing (8 and 8a)* and the *stem packing (7 and 7d)*, and replace them.
- d. Reassemble the pieces accordingly as it is indicated in point 6.

5.3 Body leakage

These DIN guided ball valves are constructed in 2 pieces, *body1 (1)* and *body2 (2)*. Body fasteners should be checked for tightness. If leakage occurs and if necessary, *body seals (14 and 34)* should be replaced as it is shown:

- a. Make alignment marks on the *body (1)* and *end cap (2)* prior to dismantling, to ensure a correct alignment when reassembling. Remove *body bolts (15)* and disassemble *body 2 (2)*.
- b. Substitute the *body seals (14 and 34)*.
- c. Reassemble the pieces accordingly as it is indicated in point 6.

5.4 Seat leakage

According to EN 12266-1 a determined seat leakage is allowed. If the leakage is higher than the maximum allowable leakage:

- a. Maintaining the valve in the closed position; loosen and remove *body bolts (15)* and remove *body2 (2)* from *body1 (1)* to check the *ball (3)* and the *metallic seats (47)*.
- b. Remove the *stem guide bolt (167)*. The *body cover 2 (128)* must be removed by loosening the *body cover 2 bolts (163)*. To remove the *ball (3)*, if necessary, bang it with a soft tool gently.
- c. If it is necessary to replace the *seats (47)*, the *ball (3)* also has to be replaced. The surface finish between both components is special and they are supplied as a collection.
- d. Assemble the pieces accordingly as it is indicated in point 6.

5.5 Body cover 2 leakage

- a. Loosen the *body cover 2 bolts (163)* to remove the *body cover 2 (128)*.
- b. Substitute the *cover seal (109)*.
- c. If the *stem bearing (127)* is damaged, the ball must be removed according to 5.4 point.

6. RE-ASSEMBLY

- a. Prior to re-assembly all components and body cavity should be cleaned of any incrustation, dirt, rust etc., especially in the locations of seats & seals.
- b. Introduce the *seat springs (45)* in the *body 1 (1)* and *body 2 (2)* housings.
- c. Introduce the *seat rings 2 (44b)* and the *seat seals (46)* in the *body 1 (1)* and in the *body 2 (2)*.
- d. Introduce the *seats (47)* in the *body1 (1)* and in the *body2 (2)*.
- e. Put the *stem seal (6)* onto the *stem (5)*. Check the antistatic devices (pos. 19, 20).
- f. Assemble the *stem (5)* into the valve as the arrow shows in the principal figure.

- g. Assemble the following components into the *body 1 (1)* introducing them through the stem (5) in this order: *stem packing (7)*, *gland packing (8)*, *stem packing d (7d)*, *gland packing a (8a)* and *spring washers (9)*, putting the *stem (5)* in closed position.
- h. Assemble the *stem bearing (165)* in the *cover (11)*, and put both of them in the body introducing through the *stem (5)*. Match them to the *body 1 (1)* by means of the *cover bolts (13)*.
- i. Introduce carefully the *ball (3)* into the *body 1 (1)* aligning the ball groove with the *stem (5)*. Join the *stem (5)* and the *ball (3)* by means of the *stem guide bolt (167)*.
- j. Place in the *body cover 2 (128)* the *cover seal (109)* and the *stem bearing (127)*.
- k. Introduce the *body cover 2 (128)* in the *body (1)* aligning it with the *ball (3)*.
- l. Join the *body (1)* and the *body cover 2 (128)* by means of the *body cover 2 bolts (163)*.
- m. Put the *body seals (14 and 34)* into their housing of the *body 1 (1)*.
- n. Maintaining the valve in its closed position and ensuring that alignment marks are matched, joint the *body 1 (1)* and the *body 2 (2)*. Assemble the *body bolts (15)* evenly tighten in diagonal using a torque wrench and the values indicated attached in document DC-08-07-03 PF "Screw torque".
- o. Put the *subjection ring (50)*.
- p. Screw the *drain plug (86)*.
- q. If the valve contains handle, put the *handle (16)* into its housing in the *stem (5)*, and tighten the *handle bolt (17)*.
- r. Slowly cycle the valve until completing 1 cycle to ensure coupling between the *seats (47)* and the *ball (3)*.
- s. Carefully cycle the valve twice in order to check the correct working. Stem should rotate smoothly offering resistance as indicated by the manufacturers torque figures. Tests should be carried out according to EN 12266-1 before reinstallation.

The end user is responsible, in case that the fluid is not communicated, checking the compatibility of the service media/ fluid with the valve materials.